



CITY OF DANBURY
155 DEER HILL AVENUE
DANBURY, CONNECTICUT 06810

CHARLES J. VOLPE, JR
PURCHASING AGENT

(203) 797-4571 PHONE
(203) 796-1527 FAX
c.volpe@ci.danbury.ct.us

May 29, 2014

ADDENDUM #1

To

Bid #03-13-14-01 "Reroofing Morris Street School"

This addendum shall be part of the Purchasing documents for the above captioned Bid. This addendum is to be acknowledged by the bidder by signing as provided below and returning with the bidder's proposal.

SEE ATTACHED: ADDENDUM NO. 1, dated May 29, 2014, 1-page

May 22, 2014 Mandatory Pre-Bid Meeting Sign-In sheet, 2-pages.
Bids from vendors who did not attend the mandatory pre-bid meeting will not be accepted.

BID DUE DATE: Remains the same, Thursday, June 5, 2014, 10:00 AM

Receipt of the addendum is hereby acknowledged.

Bidder _____

Signature _____

Title _____

Date _____

Charles J. Volpe, Jr.
Purchasing Agent
City of Danbury

29 May 2014

ADDENDUM NO. 1

Re: Roof Replacement
Morris Street School
Danbury, CT
Bid No: 03-13-14-01
State BSF No: TMP-304-XBDF

This addendum contains 1 page. This addendum is issued with the understanding that it becomes as much a part of the specification as if it were included therein originally.

Please be advised that the following questions were asked concerning the specifications:

Question 1: Timing – 63 days allowed as shown in the information for bidders section, time item #11; versus 45 days in proposal form. Please clarify.

Answer: *(63 days as outlined in the Information For Bidders, item #11, is the correct number of allowable days)*

Question 2: Rigid Insulation: Roof #1 – is there 1 ½” rigid insulation on this roof presently?

Summary of Work , Section A, item #6 – instructs to repair/ replace deteriorated rigid insulation per unit cost. Section A, Item #1 instructs to remove and dispose of existing shingle roof and underlayments to the plywood deck.

Answer: *(Yes, 1-1/2” rigid fiberglass insulation exists between the existing plywood deck and underlying wood plank deck, the contractor will only be removing to the plywood deck, however repair replacement of either component is only anticipated at locations of wet/deteriorated plywood, should it be found during demolition and is covered under Unit Pricing. So.....to clarify, the existing components to be fully removed include; shingles and underlayment felts. Plywood and insulation to remain but only removed and replaced if found damaged per Unit Pricing.)*

CITY OF DANBURY, CT

Mandatory Pre-Bid Meeting

Bid #03-13-14-01 "Reroofing Morris Street School"

DATE: Thursday, May 22, 2014, 1:00 PM

1062

NAME	COMPANY / ADDRESS	PHONE NUMBER	E-MAIL ADDRESS
Charles Volpe	Purchasing Dept City of Danbury Roxbury	203-797-4571	c.volpe@danbury-ct.gov
Richard Anderson	15. Arkonville	203 053-6900	
Miroslaw Spittke	Sikora Roofing	603 735-0552	Tom PRC 1@yahoo.com
Thomas Manzi	Powertek Roofing	860-513-8349	youngdevelopers@yahoo.com
Boogey Keyuhn	42 Chestnut Hemelton, CT	888 503 5908	youngdevelopers@yahoo.com
Peter Gebhardt	Allied Restoration East Hartford	(866) 291-8833	Peter gebhardt@alliedrestoration.net
Mike Geragys	QUALITY ROOFING SERVICES, INC. 599 ISLAND WALKWAY WEST HAVEN CT	203-931-7663	mike G @ quality roofing.com
Dan Kerr	Greenwood Industries 86a Leonardo Drive North Haven CT	(508) 328-3835	dkerr@greenwood-industries.com
Joel Booska	Bealieu Company, LLC 132 1/2 Pine St. Manchester, CT	860-798-7100	GTRMIKE@AOL.COM
John Snyder	JKS Restoration Danbury, CT	800-462-1204	jsnyder@JKSRestoration.com

