



CITY OF DANBURY
155 DEER HILL AVENUE
DANBURY, CONNECTICUT 06810

CHARLES J. VOLPE, JR
PURCHASING AGENT

(203) 797-4571 PHONE
(203) 796-1527 FAX
c.volpe@danbury-ct.gov

August 16, 2016

ADDENDUM #4

To

Bid #07-16-17-01 "Danbury Public Schools – Shelter Rock Modular Classrooms Project"

This addendum shall be part of the Purchasing documents for the above captioned Bid. This addendum is to be acknowledged by the bidder by signing as provided below and returning with the bidder's proposal.

SEE ATTACHED: Questions / Answers, 1-page

SITE VISIT: A non-mandatory site tour will be conducted at 10 :00 AM on Friday, August 19, 2016 at the job site on 2 Crows Nest Lane, Danbury, CT

BID DUE DATE: Has been changed to : 10:00 AM, Thursday, August 25, 2016

Receipt of the addendum is hereby acknowledged.

Bidder _____

Signature _____

Title _____

Date _____

Charles J. Volpe, Jr.
Purchasing Agent
City of Danbury

ADDENDUM #4

To

Bid #07-16-17-01 “Danbury Public Schools – Shelter Rock Modular Classrooms Project”

Questions / Answers

- Q. There is detail about demolition and I don't see any notes on the drawings about what is being demolished?**
- A. There is no proposed demolition. There will be some miscellaneous cutting and patching as required for electrical service from the school.
- Q. Should I price the building to the specs provided or the plans provided. Flooring is different, siding is different etc.**
- A. All pricing shall be per the written specifications for finishes, etc.
- Q. Please clarify if I can come off of the transformer or tie back into the school. If school please let me know distance to the electrical room.**
- A. The contactor shall make this decision as part of the electrical design based on the needs of the portable classrooms and the existing conditions. They should consult with Eversource if required.
- Q. Please let me know the make and the model of the fire alarm and distance to the hub.**
- A. Contractors can determine this at the prebid tour.