



# CITY OF DANBURY

DANBURY, CONNECTICUT 06810

Fire Marshal's Office  
155 Deer Hill Avenue

Barry W. Rickert, Fire Marshal  
(203) 796-1541  
Fax (203) 796-1561

Date: September 26, 2006  
To: Common Council  
From: Barry Rickert, Fire Marshal  
Re: Fire Marshal's Monthly Report  
cc: Peter J. Sicienski, Fire Chief

I hereby submit my report as Fire Marshal of the City of Danbury Fire Department for the report period covering August 21, 2006 to and including September 23, 2006.

Abatements/Reports (hrs.):	99	<u>INSPECTIONS:</u>	
Tickets Issued in Fire Lanes:	10	Places of Assembly:	74
Fire Investigations:	15	Educational:	28
Fatal Fires:	0	Business:	19
Liquor Inspections:	21	Storage:	0
Blasting Permits:	3	Healthcare:	2
Complaints:	51*	Industrial:	3
Plan Review (hrs.):	164	Mercantile:	21
Fire Prevention Programs:	22	Residential Board & Care:	0
Orders of Abatement:	5	Hotels (units):	171
		Apartments:	238
		Daycare:	5
		Misc. Inspections:	76
		Special Structures &	
		High Rise Bldg:	0
		Office Duty (hrs):	200

\* Resolved or in process of being resolved.

All members of the Fire Marshals Office received training regarding the implementation of the new Fire Code.

There was also in-house training regarding the review of construction and site plans.

PUBLIC EDUCATION


Deputy Fire Marshals Rao and Perry attended the Fire Safety booth at the Taste of Danbury. "Sparky," was also in attendance. We are currently planning our program for the Fire Prevention Month, (October). This will include a wide range of activities starting in our school system.

MISCELLANEOUS ACTIVITIES

Deputy Fire Marshals Rao and Perry, in cooperation with the Danbury Police, conducted a sweep of Nightclubs this past month. Several violations were noted and corrected.

Fire Marshal Rickert testified before the State Liquor Commission regarding Club 11. Immediately after his testimony, which included a list of violations, fire alarm system, sprinkler system, emergency light fixtures, all of which were in disrepair, the Liquor Permit was revoked for this location. The proprietors may not reapply, anywhere in Connecticut for one year. The Club may reopen under new management if the code violations are corrected.

Respectfully submitted,



Barry W. Rickert  
Fire Marshal

BR/ft  
fmrept