

CITY OF DANBURY
DEPARTMENT OF PUBLIC WORKS



155 DEER HILL AVENUE
DANBURY, CONNECTICUT 06810
(203) 797-4537 FAX (203) 796-1586

MAYOR
Honorable Mark D. Boughton

PUBLIC WORKS DIRECTOR
Antonio Iadarola, P.E.

January 30, 2007

Honorable Mayor Mark D. Boughton
Honorable Members of the Danbury Common Council
155 Deer Hill Avenue
Danbury, CT 06810

RE: Monthly report for the month of December 2006

Dear Mayor Boughton and Members of the Common Council:

I am pleased to present to you the Public Works Department report for the month of December.

The warm weather has allowed the Highway Department to continue to install additional drainage in our City streets. Unfortunately, we have depleted our drainage account and we will need more funds in order to perform additional drainage work in the spring. As the winter comes to an end, we will try to transfer money to fund more of this work.

The residents are already reaping the rewards of the drainage work performed. We no longer have icing issues or dangerous road conditions at the repaired locations. The drainage at 206 Osborne Street is completed and the problem has been eliminated. The newly installed drainage, which is designed for a 25-year storm, performed very well during the last few rain events. Miss Lila Joan Shaker, the impacted resident, is very happy with the result.

The Public Works Department, in the month of December, also dealt with a complicated drainage repair that was causing a dangerous situation on a resident's driveway. The driveway at 16 Tanglewood Drive was found to be collapsing due to large separations in the joints of the 30- inch concrete pipes that are over 12 feet under the ground.

The Public Utilities Department partnered with the Highway Department and used some of their sophisticated equipment to view the inside of the pipe. They found many joints in the pipes were open and directly contributing to the collapsing driveway. In order to dig the pipes up and fix them, they would have to dig over 12 feet into the ground and could require sheet piles to do the work safely.

After conducting some research, we consulted with a specialty vendor to develop a method of repair that did not require any digging. The work was to be performed from inside the pipe. Special equipment was used to install a bladder in the pipe at the joints to seal them and fill the voids in the soil around the pipe.

It took over 414 gallons of grout to seal this pipe. The cost was approximately \$10,550 to complete and we estimate that it would have cost over \$125,000 to dig the pipe up and reinstall it.

I continue to focus on resolving major drainage issues that exist on our City roads and impacting residents' property. I have been studying the severe icing condition on East Pembroke Road that is related to poor drainage.

Should you have any questions regarding this report or any of the separately submitted divisions reports, please call me at 797-4537.

Engineering Report submitted by the Farid L. Khouri, P.E. City Engineer:

Assessment Projects: The Nancy Drive/Carolyn Avenue area sanitary sewer assessment project is shut down for the winter months. The Old Farm Road sanitary sewer assessment project was awarded to Anthony Julian Railroad Construction Company and work will begin by the end of January 2007. The Kenosia Avenue sanitary sewer assessment project final plans are complete and the project is out to bid. The bids are to be opened in February 2007.

Regarding Engine 26, structural steel has been erected and some masonry walls are up.

With respect to the Library Place Parking Garage, 80% of the footing and foundation walls are completed. We are happy to point out that the electrical easement has been secured and recorded with the City. Utility trenching is underway and 70% complete.

Regarding the Kaplanis Memorial Field project, the contractor completed laying the artificial turf and the infill operation is underway. The flagpole has been ordered and landscaping will be done in the spring.

The Rogers Park Middle School renovations are well underway, with the majority of the work to be done by February 2007. The Roberts Avenue Replacement School Phase II plans and specifications are complete and we expect to bid the project soon.

The Police Department Headquarters 80% preliminary design is complete. Demolition of the buildings on North Main Street and Franklin Street is almost done. We are currently working on miscellaneous permits and approvals for the new building.

Should you have any questions regarding this report or any of its contents, or any other issues related to your Engineering Department for that matter, please do not hesitate to contact me at (203) 797-4641.

Highway Department report submitted by Duke Hart, Superintendent of Highway:

The favorable weather conditions, in December, provided the Highway Department the opportunity to work on several projects. We were able to continue with the installation of new drainage at Cel-Bret Dr. and Briar Ridge Rd. In addition, we completed the Osborne St. drainage project. Catch basins were repaired at four locations and we backfilled over 6,000 L.F. of curb. New street signs were installed at 14 locations along with repairs to signs and posts at 75 other locations. The Permit Department issued 9 new permits to contractors. The crews have been doing an excellent job with the leaf bag program, which is in the final month. With the weather staying fairly dry and somewhat warm, we are able to continue sweeping the leaf-covered streets. We have been aggressively picking up litter and debris on our roads and right of ways. The results are very noticeable and enhance the appearance of the City. I would like to thank the Park Maintenance Department and the Forestry Department for all the assistance they have provided us.

I would also like to take this opportunity to thank the Highway Department employees for their generous donations to our toy drive for the children of Danbury. We have been doing this for three years and this year's collection went above and beyond our expectations, surpassing the previous years. I can't thank them enough for their generosity.

Should you have any questions regarding this report, please feel free to contact me at 797-4605.

Parks and Recreation Maintenance report submitted by Joseph Pacific, General Foreman:

The mild weather in December provided the Park Maintenance Department with the opportunity to partner with the Forestry Division in the removal of tree stumps. We were also pleased to provide two crews to assist with tree removals. The Parks Maintenance crews worked diligently to remove metal edgings around the Green, Danbury High School courtyard and Hayestown Avenue School in order to reduce the tripping hazard that has existed for quite some time. We partnered with the Highway Department

assisting with the back filling of curbs in the Aunt Hack area. I have been attending classes to become familiar with the new Kronos system. Finally, we are in the process of maintaining and power washing our equipment so that it is ready for the up-coming season.

Should you have any questions regarding this report, please feel free to contact me at 796-1558.

Forestry Department report submitted by Mark Miller, Foreman Forestry Department:

The Tree Department removed the following trees: a 46' ash on Spruce Mountain Rd., a 40' black walnut and 36' ash on Chambers Rd., two 30' maples on Great Meadow and Great Plain Rds., a 36' Norway maple on Durant St., a 30' oak at 226 Great Plain Rd., a maple on Mallory St. and a dead ash on 22 Woodside Ave.

On December 6th we moved a Crab Apple tree from the site of the new parking garage. We will replant it at the Beaver Street Park.

Two large butts were removed at King Street School near the ball fields along with a large willow in Rogers Park that fell during a windstorm. We removed and cut back trees on Briar Ridge Rd. for a Highway Department project and on Osborne St. for a storm sewer project. Two maples were pruned on Hill Top Manor. We also pruned and removed heavy dead wood from a tree on 25 Edgewood St. The Tree Department did some trimming to cut a site line at 24 Cedar Dr. Harwood Dr. and Great Meadow Rd. were trimmed back for snow plowing. We are currently concentrating our efforts on Joe's Hill Rd., from the New York line to Mill Plain Rd., trimming and cutting back to improve site lines and to prepare for snow plowing. We appreciate the assistance of the Park Maintenance Division with the tree and stump removals.

Should you have any questions regarding this report, please feel free to contact me at 797-4609.

Public Buildings report submitted by Rick Palanzo, Superintendent of Public Buildings:

Attached please find the statistical analysis for repairs and maintenance work that the Public Buildings Mechanics engaged in during the month of December. In the month of December we received 103 new work requests and completed 242 work requests. In reviewing this report, you will find the repair time that was expended in major work categories, (current month versus previous month). Also listed is the total number of work order hours completed, (current month versus the previous month).

Our department was heavily engaged in mechanical repairs of the City's buildings and schools with a total of 209.50 man-hours dedicated to this service. The next largest area

of concentration was in plumbing repairs, utilizing 125.25 man-hours of labor. Electrical repairs were the third highest category with 107.00 man-hours.

Should you have any questions regarding this report, please do not hesitate to contact me at 797-4584.

See appendix "A" for attachments

Public Utilities report submitted by David Day, Superintendent of Public Utilities:


The Public Utilities Department continues to service fire hydrants throughout the city. As of this month there are 77 hydrants out of service. Repairs to hydrants are continuing.

Attached you will find reports from the Water Department and Equipment Maintenance Department.

Should you have any questions regarding this report, please do not hesitate to contact me at 797-4539

See appendix "B" for attachments

Sincerely,



Antonio Iadarola, P.E.

Director of Public Works

AI/dgs

Cc: Farid Khouri – Engineering

Rick Palanzo – Public Buildings

David Day – Public Utilities

Joe Pacific – Parks & Rec. Maintenance

Mark Miller – Forestry Dept.

Appendix “A”
Public Buildings Attachments

CITY OF DANBURY DECEMBER 06 MONTHLY REPORT

	Labor Hours	Total Hours This Month	Total Hours Last Month	Difference	Percent Change
Administration		160.00	165.00	0.00	0.00
City Bldgs	80.00				
Schools	80.00				
Carpentry		0.00	43.00	-43.00	0.00
City Bldgs	0.00				
Schools	0.00				
Electrical		107.00	205.50	-98.50	-92.06
City Bldgs	0.00				
Schools	107.00				
Alarms		0.00	0.00	0.00	0.00
City Bldgs	0.00				
Schools	0.00				
HVAC		0.00	24.50	-24.50	0.00
City Bldgs	0.00				
Schools	0.00				
Locksmith		8.00	3.50	4.50	56.25
City Bldgs	0.00				
Schools	8.00				
Maintenance		0.00	0.00	0.00	0.00
City Bldgs	0.00				
Schools	0.00				
Mechanical		209.50	272.00	-62.50	-29.83
City Bldgs	0.00				
Schools	209.50				
Flowing		0.00	0.00	0.00	0.00
City Bldgs	0.00				
Schools	0.00				
Plumbing		125.25	143.50	-18.25	-14.57
City Bldgs	0.00				
Schools	125.25				
Roofing		0.00	0.00	0.00	0.00
City Bldgs	0.00				
Schools	0.00				

total work hours 609.75

Appendix “B”
Public Utilities Attachments



CITY OF DANBURY
DEPARTMENT OF PUBLIC UTILITIES
155 DEER HILL AVENUE
DANBURY, CT 06810

(203) 797-4637
FAX (203) 796-1590

TO : Common Council - City of Danbury
FROM : David Day, Superintendent of Public Utilities
DATE : January 17, 2007
RE : WATER DEPARTMENT REPORT : DECEMBER 2006

I. WATER PRODUCTION :

A) Margerie Water Treatment Facility :	<u>105.1</u>	<u>MG.</u>
B) West Lake Water Treatment Facility :	<u>114.8</u>	<u>MG.</u>
C) Kenosia Well Field :	<u>0</u>	<u>MG.</u>
D) Osborne Street Well Field :	<u>0</u>	<u>MG.</u>
E) Other :	<u>0</u>	<u>MG.</u>

(MG. = Million Gallons)

II. RAINFALL :

A) Month :	<u>1.9</u>	<u>inches</u>
B) Past 12 Month Period :	<u>64.9</u>	<u>inches</u>
C) Current Year (Jan.- Current Mo.) :	<u>57.3</u>	<u>inches</u>

III. WATER STORAGE :

A) Margerie Reservoir :	<u>100.0</u>	<u>%</u>
B) West Lake Reservoir :	<u>97.1</u>	<u>%</u>
C) East Lake Reservoir :	<u>99.4</u>	<u>%</u>
D) Total :	<u>98.6</u>	<u>%</u>

date: 12/1/2006

IV. WATER PUMPED :

A) Park Avenue Pump Station :	<u>0</u>	<u>MG.</u>
B) Padanaram(High School) Pump Station :	<u>4.21</u>	<u>MG.</u>
C) Shelter Rock Pump Station :	<u>2.82</u>	<u>MG.</u>
D) WestConn Pump Station :	<u>1.47</u>	<u>MG.</u>
E) Margerie Pump Station :	<u>1.26</u>	<u>MG.</u>
F) Pleasant Acres:	<u>2.65</u>	<u>MG.</u>
G) Nabby Road:	<u>1.00</u>	<u>* MG.</u>
H) Harvest Hill:	<u>2.61</u>	<u>MG.</u>
I) West Lake High Service :	<u>54.7</u>	<u>MG.</u>

(MG. = Million Gallons)
* = Estimated

V. WATER TRANSFERRED :

A) East Lake to Margerie Reservoir :	<u>0</u>	<u>MG.</u>
B) Padanaram to Margerie Reservoir :	<u>0</u>	<u>MG.</u>
C) Kohanza to West Lake Reservoir :	<u>0</u>	<u>MG.</u>
D) Kenosia Diversion to West Lake Reservoir :	<u>0</u>	<u>MG.</u>
E) Kenosia Wells to West Lake Reservoir :	<u>0</u>	<u>MG.</u>

(MG. = Million Gallons)

VI. ALGAE CONTROL :

- A) NONE
- B) _____
- C) _____

VII. SURVEY OF WATER SOURCES :

- A) Quarterly radiological testing of water plant treated water.
- B) _____

VIII. SUPERINTENDENTS NOTES :



CITY OF DANBURY
DEPARTMENT OF PUBLIC UTILITIES
155 DEER HILL AVENUE
DANBURY, CT 06810

(203) 797-4637
FAX (203) 796-1590

M E M O R A N D U M

DATE: January 2, 2007
TO: City of Danbury, Common Council
FROM: David M. Day, P.E., Superintendent – December 2006
RE: Sanitary Sewer Collection System Maintenance

Complaints: 12

Number Received: 12

Number Completed: 12

Pipe Cleaned: 1000 LF

Gallons of Water Used: 18,000

Pipe Inspected:

COMMENTS:

JAN 17 2007

Discard Date _____
Permanent _____
File Code _____



To: David Day, P.E., Supt. of Public Utilities, City of Danbury
 From: Anthony J. Bozza, Project Manager *Anthony J. Bozza*
 Subject: WPCP Report For Month of: December, 2006
 Date: 01/12/07

I. Wastewater Treatment:

A) Sewage Processed:	9.3 MGD (Daily Avg)	288.6 Million Gallons Total
B) Septic Waste Processed:		859,775 Gallons Total
C) Sludge Pumped To Digesters:		577,353 Pounds Total

II. Wastewater Quality

	Influent	Effluent	% Removal	Effluent Limit
A) BOD (mg/l)	240	11	95	30 mg/l and 85%
B) Total Suspended Solids (mg/l):	270	8	96.9	30 mg/l and 85%
C) Total Phosphorus (mg/l):	6.2	2.9	53	1.0 mg/l
D) Ammonia (mg/l):	22.0	0.11	100	4.0 mg/l
E) Total Nitrogen (lbs/Day):	2,830	1,692	40	651 lbs/day

Note: Phosphorus limits apply May - September. Nitrogen limit for credit trading only.

III. Pump Station Operation:

A) Beaver Brook:	769.3 Hours Run
B) Southfield:	23.0 Hours Run
C) Mill Plain:	749.6 Hours Run
D) Backus:	110.3 Hours Run
E) Tarrywile	103.9 Hours Run
F) Turner Road:	39.6 Hours Run
G) Ford Avenue:	23.6 Hours Run
H) Indian Glen:	98.7 Hours Run
I) Delay Street:	27.0 Hours Run
J) Hayestown Road:	42.3 Hours Run
K) Kenosia Avenue:	3.1 Hours Run
L) Larson Drive:	61.8 Hours Run
M) Landfill:	138.1 Hours Run

Total Station Alarms: 11

MAINTENANCE GARAGE #6 REPAIR

12/1/2006	132DA	WATER	TRANNY
	101DA	WATER	SERVICE BRAKES TIRES
	5DA	POLICE	INTAKE MANIFOILD
	8DA	POLICE	INTAKE MANIFOILD
12/4/2006	337DA	POLICE	OVERHEATING
	101DA	WATER	SERVICE BRAKES TIRES
	5DA	POLICE	INTAKE MANIFOILD
	186DA	POLICE	LIGHTS
12/5/2006	2DA	POLICE	WIPERS ENGINE LIGHT
	337DA	POLICE	OVERHEATING
	101DA	WATER	SERVICE BRAKES TIRES
	263DA	HEALTH	ALTERNATOR
12/6/2006	2DA	POLICE	WIPERS ENGINE LIGHT
	9DA	POLICE	SERVICE
	107DA	WATER	BODY DOORS
	5DA	POLICE	INTAKE MANIFOILD
12/7/2006	11DA	POLICE	SERVICE
	5DA	POLICE	INTAKE MANIFOILD
	132DA	WATER	TRANNY
12/8/2006	240DA	POLICE	SERVICE BRAKES
	132DA	WATER	TRANNY
	10DA	POLICE	WINDOW REGULATOR
12/11/2006	10DA	POLICE	WINDOW REGULATOR
	4DA	POLICE	SERVICE
	132DA	WATER	TRANNY
	55DA	HEALTH	ALTERNATOR
12/12/2006	217DA	WATER	NO START SERVICE
	5DA	POLICE	ANTIFREEZE LEAK
	334DA	POLICE	OIL LEAK
		POLICE	MIRRIOR
12/13/2006	334DA	POLICE	OIL LEAK
	217DA	WATER	SERVICE BRAKES
	159DA	WATER	SERVICE TIRES
12/14/2006	350DA	WATER	WATER PUMP
	15DA	POLICE	SERVICE BRAKES
	265DA	POLICE	FLAT
12/18/2006	11DA	POLICE	REAREND
	12DA	POLICE	SERVICE BRAKES
		DET	SERVICE
	217DA	WATER	CRANKSHAFT SENSIOR
	350DA	WATER	TEMP SENSIOR
12/19/2006	12DA	POLICE	SERVICE BRAKES
	192DA	AIRPORT	STEERING PUMP WINDOW REGULATOR SERVICE
		DET	SERVICE DOOR LOCK
12/20/2006	192DA	AIRPORT	STEERING PUMP WINDOW REGULATOR SERVICE
		DET	DOOR LOCK
	190DA	POLICE	SERVICE

12/21/2006	5DA	POLICE	BRAKES
	240DA	POLICE	IDLER PULLY
12/26/2006	11DA	POLICE	REAREND
	55DA	HEALTH	STARTER
	5DA	POLICE	BRAKES
12/27/2006	5DA	POLICE	BRAKES
	337DA	POLICE	ENGINE LIGHT
	11DA	POLICE	REAREND
	95DA	WATER	FUEL PUMP
	127DA	PERMIT	EXHAUST
12/28/2006	337DA	POLICE	ENGINE LIGHT
	95DA	WATER	FUEL PUMP
	126DA	WATER	ENGINE LIGHT
12/29/2006		DET	FRONTEND
	11DA	POLICE	REAREND
	126DA	WATER	ENGINE LIGHT SERVICE

EQUIPMENT MAINTENANCE
BUILDING #4
DECEMBER 2006

<u>DATE</u>	<u>VEHICLE</u>	<u>REPAIR DONE</u>	<u>DEPT.</u>
12/1/2006	90-I-25	SERVICE TENCO BODY/LIGHTS	HIGHWAY
	00-I-87	REPLACE BATTERIES/ALTERNATOR	HIGHWAY
	56DA	SERVICE/TIRES/SIDE DUMP CHAIN	PARKS
	106DA	SERVICE	HIGHWAY
	01-F-24	4 REAR TIRES	HIGHWAY
	94-I-48	REMOVE LEAF BOX	HIGHWAY
	06-E-40	SWEEPER BROOM	HIGHWAY
	94-I-15	REMOVE LEAF BOX	HIGHWAY
	94-I-6	REMOVE LEAF BOX	HIGHWAY
	172DA	LIGHTS	PARKS
	94-I-15	MOUNT SANDER	HIGHWAY
12/4/2006	56DA	SERVICE/TIRES/SIDE DUMP CHAIN	PARKS
	172DA	LIGHTS/REPLACE BATTERY	PARKS
	06-E-40	MAIN BROOM	HIGHWAY
	96-I-20	ROAD SERVICE-JUMP START/ALTERNATOR	HIGHWAY
	90-I-44	ROAD SERVICE/POWER STEERING HOSE	HIGHWAY
	180DA	HYDRAULIC PROBLEM	HIGHWAY
	96-I-33	LIGHTS	HIGHWAY
	94-I-15	MOUNT SANDER	HIGHWAY
	90-I-47	REPLACE OIL PAN	HIGHWAY
	90-I-17	MIRROR/CONVEYOR DOOR LATCH	HIGHWAY
12/5/2006	90-I-17	MIRROR/CONVEYOR DOOR LATCH	HIGHWAY
	94-I-15	MOUNT SANDER	HIGHWAY
	90-I-47	REPLACE OIL PAN	HIGHWAY
	94-I-6	OIL PAN/MOUNT SANDER/BRAKE CHAMBERS	HIGHWAY
	94-I-48	MOUNT SANDER	HIGHWAY
	90-I-44	TAILGATE LATCHES	HIGHWAY
	248DA	REPLACE BATTERY	BLDG INSP
	187DA	SERVICE	PARKS
	90-I-25	HYDRAULIC PROBLEM	HIGHWAY
12/6/2006	187DA	SERVICE	PARKS
	94-I-6	OIL PAN/MOUNT SANDER/BRAKE CHAMBERS	HIGHWAY
	00-I-19	ENGINE OIL LIGHT ON	HIGHWAY
	94-I-15	REPLACE HEADLIGHT BUCKET	HIGHWAY
	65DA	ROAD SERVICE-MAJOR COOLANT LEAK	FORESTRY
	93-IR-212	WATER SYSTEM	HIGHWAY
	05-I-10	LIGHTS	HIGHWAY
	272DA	SERVICE	PARKS
	03-S-30	SERVICE TENCO BODY	HIGHWAY
12/7/2006	03-S-30	SERVICE TENCO BODY	HIGHWAY
	272DA	SERVICE/FUEL TANK STRAP/WHEEL GREASE SEAL	PARKS
	90-I-25	HYDRAULIC PROBLEM	HIGHWAY
	PARKS	ROAD SERVICE-TOURCH CUT POSTS	PARKS
	03-I-14	COOLANT OVERFLOW BOTTLE	HIGHWAY
	SHOP	FABRICATE HOSE REEL ASSY	EQUIP MAINT
	00-I-7	SERVICE	HIGHWAY
12/8/2006	03-I-14	REPLACE COOLANT OVERFLOW BOTTLE	HIGHWAY
	00-I-7	EXHAUST BRAKE INOP.	HIGHWAY
	SHOP	FABRICATE HOSE REEL ASSY	EQUIP MAINT
	106DA	CHECK NOISE IN FRONT END	HIGHWAY

EQUIPMENT MAINTENANCE

BUILDING #4

DECEMBER 2006

	198DA	SERVICE	PARKS
	04-JD-67	SET TIRE PRESSURES	HIGHWAY
	05-I-31	MOUNT SANDER	HIGHWAY
	90-I-5	ELECTRICAL PROBLEM	HIGHWAY
12/11/2006	90-I-5	ELECTRICAL PROBLEM	HIGHWAY
	05-I-31	MOUNT SANDER	HIGHWAY
	05-I-26	CHECK BRAKES/ADJUST	HIGHWAY
	90-I-25	REPLACE DUMP CYLINDER	HIGHWAY
	94-I-48	REPLACE PLOW LIFT CYLINDER	HIGHWAY
	97-I-2	REPLACE PLOW HOSES	HIGHWAY
	92DA	INSTALL PLOW CUTTING EDGE/DOOR HANDLE	FORESTRY
	85-F-43	SERVICE	HIGHWAY
12/12/2006	85-F-43	SERVICE	HIGHWAY
	92DA	INSTALL PLOW CUTTING EDGE/DOOR HANDLE	FORESTRY
	01-E-83	REMOVE STROBE LIGHT ASSY	HIGHWAY
	06-E-40	SIDE BROOM	HIGHWAY
	252DA	SERVICE	PUBLIC BLDG
	05-D-98	REPLACE 4 TIRES	HIGHWAY
	42DA	REPAIR HYDRAULIC LEAK	FORESTRY
	SHOP	FABRICATE PLOW PINS	EQUIP MAINT
	90-I-5	RE-WIRE FRONT LIGHTS	HIGHWAY
	03-F-35	READY FOR WINTER	EQUIP MAINT
12/13/2006	97-I-85	REPAIR ELECTRICAL PROBLEM	HIGHWAY
	00-I-3	ROAD SERVICE-JUMP START	HIGHWAY
	90-I-5	RE-WIRE FRONT LIGHTS	HIGHWAY
	00-I-7	REPAIR ENGINE EXHAUST BRAKE	HIGHWAY
	94-I-91	REPAIR COOLANT LEAK/REPLACE AIR DRYER	HIGHWAY
	SHOP	FABRICATE PLOW PINS	EQUIP MAINT
	03-F-35	READY FOR WINTER	EQUIP MAINT
	05-F-46	SERVICE	HIGHWAY
	06-E-40	SIDE BROOM	HIGHWAY
12/14/2006	03-F-35	READY FOR WINTER	EQUIP MAINT
	00-I-3	REPLACE BATTERY	HIGHWAY
	171DA	SERVICE	FORESTRY
	SHOP	CHECK BACK-UP GENERATOR	EQUIP MAINT
	90-I-47	RE-WIRE FRONT LIGHTS	HIGHWAY
	00-I-16	ABS LIGHT ON	HIGHWAY
	04-JD-67	REPAIR HYDRAULIC LEAK	HIGHWAY
	97-I-23	REPAIR CAB SHIELD	HIGHWAY
12/15/2006	97-I-23	REPAIR CAB SHIELD	HIGHWAY
	00-I-16	ABS LIGHT ON	HIGHWAY
	05-F-54	REPAIR CAB LIGHT	HIGHWAY
	94-I-91	REPLACE DEBRIS SUCTION HOSE/COLLAR	HIGHWAY
	42DA	DIAGNOSE SLOW HYDRAULICS	FORESTRY
	04-JD-67	ROAD SERVICE-AIR-UP TIRES	HIGHWAY
	97-I-27	REPLACE WINDOW REGULATOR/HANDLE	HIGHWAY
	97-E-100	INSTALL STROBE LIGHT/ADJUST CHAINS	HIGHWAY
12/18/2006	97-E-100	INSTALL STROBE LIGHT/ADJUST CHAINS	HIGHWAY
	97-I-27	SECURE INNER DOOR PANEL	HIGHWAY
	97-I-23	REPAIR CAB SHIELD	HIGHWAY
	SHOP	FABRICATE BRACKET	EQUIP MAINT

EQUIPMENT MAINTENANCE
BUILDING #4
DECEMBER 2006

	90-I-47	RE-WIRE FRONT LIGHTS	HIGHWAY
	06-E-40	ROAD SERVICE-CHECK PTO	HIGHWAY
	56DA	ROAD SERVICE-FLAT TIRE	PARKS
	97-I-27	STROBE LIGHT INOP.	HIGHWAY
	90-I-28	RE-WIRE FRONT LIGHTS	HIGHWAY
	124DA	ROAD SERVICE-BRAKE PROBLEM	AIRPORT
12/19/2006	97-I-23	REPAIR CAB SHIELD	HIGHWAY
	90-I-28	RE-WIRE FRONT LIGHTS	HIGHWAY
	124DA	ROAD SERVICE-BRAKE PROBLEM	AIRPORT
	06-E-40	HEATER KNOB/DIRT DEFLECTOR WEIGHT	HIGHWAY
	90-I-12	RE-WIRE FRONT LIGHTS	HIGHWAY
	92DA	CHECK BRAKES/SERPENTINE BELT	FORESTRY
	90-I-37	HYDRAULIC LEAK/RE-WIRE FRONT LIGHTS	HIGHWAY
12/20/2006	90-I-37	HYDRAULIC LEAK/RE-WIRE FRONT LIGHTS	HIGHWAY
	06-E-40	STRAIGHTEN STEP ASSY	HIGHWAY
	03-I-9	REPLACE PLOW HOSES	HIGHWAY
	90-I-28	REPLACE PLOW HOSES	HIGHWAY
	97-I-86	REPLACE PLOW HOSES	HIGHWAY
	05-F-54	REPAIR LIGHTS	HIGHWAY
	97-E-100	ROAD SERVICE-SIDE BROOM INOP.	HIGHWAY
	94-I-4	MOUNT SANDER/MUDFLAP/REPAIR CHUTE	HIGHWAY
	HAND TAMPER	DRILL OUT BROKEN BOLTS	HIGHWAY
12/21/2006	94-I-4	MOUNT SANDER/MUDFLAP/REPAIR CHUTE	HIGHWAY
	HAND TAMPER	DRILL OUT BROKEN BOLTS	HIGHWAY
	PLOWS	REPLACE PLOW HOSES	HIGHWAY
	00-I-16	REPLACE MIRRORHEAD	HIGHWAY
	90-I-28	SERVICE TENCO BODY & TRUCK	HIGHWAY
	299DA	SERVICE	FORESTRY
	181DA	ADJUST BRAKES	HIGHWAY
12/22/2006	94-I-4	MOUNT SANDER/MUDFLAP/REPAIR CHUTE	HIGHWAY
	06-E-40	SIDE BROOM	HIGHWAY
	299DA	SERVICE	FORESTRY
	90-I-25	SERVICE TENCO BODY	HIGHWAY
12/26/2006	90-I-25	SERVICE TENCO BODY	HIGHWAY
	299DA	WELD DISCHARGE CHUTE	FORESTRY
	94-I-4	MOUNT SANDER/REPAIR MUDFLAP	HIGHWAY
	239DA	SERVICE	ENGINEERING
	97-I-85	ADJUST BRAKES	HIGHWAY
	05-I-32	REPAIR LIGHTS	HIGHWAY
	210DA	SERVICE/FRONT BRAKES	PUBLIC BLDG
	93-F-96	REPAIR LIGHTS	HIGHWAY
	315DA	SERVICE/REPLACE BLADES	HIGHWAY
	70-FL-00	TUNE-UP	EQUIP MAINT
12/27/2006	210DA	SERVICE/FRONT BRAKES	PUBLIC BLDG
	315DA	SERVICE/REPLACE BLADES	HIGHWAY
	70-FL-00	TUNE-UP	EQUIP MAINT
	96-I-20	SERVICE/REPLACE BATTERES/ALT.	HIGHWAY
	03-I-9	REPAIR ASPHALT DOOR	HIGHWAY
	SHOP	CLEAN OUT FLOOR DRAINS	EQUIP MAINT
12/28/2006	70-FL-00	TUNE-UP	EQUIP MAINT
	06-E-40	MAIN/SIDE BROOMS	HIGHWAY

EQUIPMENT MAINTENANCE
BUILDING #4
DECEMBER 2006

	85-F-43	PERFORMANCE PROBLEM	HIGHWAY
	70DA	ROAD SERVICE-JUMP START	HIGHWAY
	94-I-4	FRONT BRAKE CHAMBERS/RE-WIARE FRONT LIGHTS	HIGHWAY
	96-I-20	SERVICE/REPLACE BATTERES/ALT.	HIGHWAY
	94-I-6	RE-WIRE FRONT LIGHTS	HIGHWAY
	180DA	REPAIR HYDRAULIC LEAK	HIGHWAY
	94-I-48	RE-WIRE FRONT LIGHTS	HIGHWAY
12/29/2006	94-I-48	RE-WIRE FRONT LIGHTS	HIGHWAY
	94-I-4	FRONT BRAKE CHAMBERS/RE-WIARE FRONT LIGHTS	HIGHWAY
	90-I-47	SERVICE TRANSMISSION	HIGHWAY
	05-I-34	REPAIR STROBE LIGHT	HIGHWAY
	94-I-15	RE-WIRE FRONT LIGHTS	HIGHWAY
	90-I-12	SERVICE TRANSMISSION	HIGHWAY
	05-I-31	REPAIR WIRING FOR BODY MODULE	HIGHWAY